

**Notice Inviting Tender on behalf of
PRADESHIK COOPERATIVE DAIRY FEDERATION LTD.
29 PARK ROAD, LUCKNOW-226 001
(Ph.No.# 0522- 2236469, 2239666)**

Email : mmd.pcdf@paragmilkup.in

Corrigendum 1

Tender No: 001/UPICO/PCDF/BMC/2016-17

Date: 25.12.2016

In reference to the tender invited vide NIT No.001/UPICO/PCDF/BMC/2016-17, Date: 25.12.2016, the following amendments are being made in the clauses of Tender for Establishment of BMC center, as per specification, under Turn Key Project at different Distt. of U.P.

S. No.	Reference Clause in Tender Document	Reference Page in Tender Document	Existing provision in Tender Document	As Amended
1.	3 & 6	Page No. 4 & 6	Payment of tender fee of Rs. 25000 including VAT, through demand draft in favour of U.P. Industrial consultants ltd. payable at Lucknow.	Payment of tender fee of Rs. 25000 including VAT, through demand draft in favour of Pradeshik Cooperative Dairy Federation Limited. payable at Lucknow.
2.	17 Terms of payment	Page No. 36& 155	40% of the FOR order value on supply component only against the submission of equivalent Bank Guarantee valid upto supply period	40% of the FOR order value on supply component only against the submission of equivalent Bank Guarantee valid beyond three months after the supply period
3.	17 (C) payment term for civil works	Page No. 36, 37 & 156	60% of monthly bill shall be released within 15 days of submission of bills	60% of monthly bill shall be released within 30 days of submission of bills
4.	5.3 Diesel engine	Page No. 95	The diesel engine should be suitable for Power Generation application type air or water cooled and capable of developing required BHP when running at 1500 rpm under NTP conditions.	The diesel engine should be suitable for Power Generation application type air cooled and capable of developing required BHP when running at 1500 rpm under NTP conditions.
5.	5.4 Engine Instrument Panel (Mechanical and/or electronic gauges)	Page No. 95	Consist of Ignition key, Starting push button, Lubricating oil pressure gauge, Temperature gauge for cooling water, Temperature gauge for lubricating oil, RPM meter (Analog type) Battery charging ammeter	Consist of Ignition key, Starting push button, Lubricating oil pressure gauge, engine high temperature safety to be provided, Temperature gauge for lubricating oil, RPM meter (it must be electronic) Battery charging ammeter
6.	5.6 Control Panel	Page No. 95	The diesel generating set to have suitable control panel duly pre-wired with the following instruments:	The diesel generating set to have suitable control panel duly pre-wired with the following instruments:

			One ammeter with selector switch, One energy meter with selector switch, Hour meter, One suitable capacity MCCB with overload and short circuit protection to disconnect power supply in case load of generating set increases beyond permitted limits. The rupturing capacity of the MCCB should not be less than 25 kA. One set of indicating lamps and control fuses.	One ammeter with selector switch, display for ammeter and energy meter to be provided, Hour meter, One suitable capacity MCCB with overload and short circuit protection to disconnect power supply in case load of generating set increases beyond permitted limits. The rupturing capacity of the MCCB should not be less than 25 kA. One set of indicating lamps and control fuses.
--	--	--	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

The other terms and conditions will remain same as per NIT No. 001/UPICO/PCDF/BMC/2016-17.

Information or corrigendum if any shall be uploaded only on the website: www.paragmilkup.in / www.upico.org. Bidders are advised to visit the website on regular basis in order to keep themselves updated

Please keep watching for latest communication, if any

**Issued by
Sd/-
Managing Director,
UPICO
Procurement Consultant on behalf of PCDF Ltd.**